

8

Annexure C

PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

No. 43/D/SWA/NSA

Dated: 15/4/2026

It is certified that an inspection team headed by ALKA SINGH - CHEMIST

(Name of Officers with designation) from KANPUR NAGAR NIGAM PHED

Inspected the INTERNATIONAL CENTRE ENGLISH SCHOOL, B.S. Park, Arya Nagar, Kanpur

(Name & Address of the school) on 01/4/2026 (date of inspection) and on the basis of

Water Test Report (Attached) bearing no. 413/SWA/CHEM dated 10/4/2026

of Public Health Laboratory K.N.N. (PHED Lab) certified that the

International Centre English School (Name of school) has safe drinking water facilities for the students and members of staff of the institution. School is also maintains the hygienic sanitation condition in the school

building & the campus as per norms prescribed by the Central/State/U.T.Govt.

This certificate is valid till ONE YEAR

Signature with Seal: [Signature] 15/4/26
Name: [Name]
Designation: N.S.A. अधिकारी
Name & Address of the Office/Department: नगर निगम कानपुर

To INTERNATIONAL CENTRE ENGLISH SCHOOL
B.S. Park, Arya Nagar, Kanpur.
(Name & Address of the Institution)

Note: The certificate is to be issued by authorized officer/PHED Lab/local bodies



KANPUR NAGAR NIGAM

PUBLIC HEALTH LABORATORY, KANPUR NAGAR NIGAM

Chemical water analysis report for the INTERNATIONAL CENTRE ENGLISH SCHOOL
Sample taken from SUBMERSIBLE B.S. Park, Arya Nagar
Kanpur

Date of sample Drawn 01/4/2026

Date of analysis 01/4/2026

Physical Character TRANSPARENT / ODDORLESS

P. H. Value 8.42

Free Ammonia Parts per 1000000 NIL

Albuminoid Ammonia Part per 1000000 NIL

Oxygen absorbed from pot. Permagnate
in three hours at 37° C 0.8

Chloride Part per 1000000 54.00

Nitrates Parts per 1000000 TRACES

Nitrates Parts per 1000000 TRACES

Total solid part per 100000 706.00

Fixed solid Parts per 1000000 592.00

Volatils solid Parts per 100000 114.00

Appearance on ignition NO CHARRING

Total hardness Parts per 1000000 358.00

Permanent hardness Parts per 1000000 292.00

Temporary hardness Parts per 1000000 66.00

K.N.N. PRESS

Remarks : POTABLE

No. 413/SWA/Chem dated 10/4/2026

Copy forwarded for favour or information to

1) MIS International Centre English School
B.S. Park, Arya Nagar, Kanpur.

2) M.S.A. Kanpur Nagar Nigam.

10/4/26
Nagar Swasthya Adhikari
Nagar Nigam Kanpur
ALKASINGH
(Chemist)
Nagar Nigam Kanpur



KANPUR NAGAR NIGAM

PUBLIC HEALTH LABORATORY NAGAR NIGAM KANPUR

Result of Bacteriological Examination of Water Sample taken from INTERNATIONAL CENTRE ENGLISH School


Name & designation of the person collecting samples... ALKA SINGH - CHEMIST

B.S. Park, Azad Nagar
Kanpur

Date & time of collection	Source of sample	Colony count on Agar Agar per M. L. of water		Presumptive Coliform count			Probable on of coliform organism in 100 CC of original water	Free Residual Chlorine part per Million	REMARKS	
		at 37.c in 48 hours	at room temp- return in 72 hours	Quantity of water put in each tube No of tubes put up	50ML 1	10 ML 5				1 ML 5
01/4/2026	'Submersible'	'44'	'69'	—	—	'3'	'2'	'Zero'	'NIL'	'Satisfactory'

Remarks - Chlorination is very necessary | F.R.C. must be 0.2 ppm

- Copy for Information Forwarded to
- (1) International Centre English School
 - (2) M.S.A. Kanpur Nagar Nigam


 Nagar Swasthya Adhikari
ALKA SINGH
 (Chemist)
 Nagar Nigam Kanpur